



Quick Installation Guide

Solar Inverter

M50A_260 (Delta part number RPI503M260000, product version L and M)



Europe



This quick installation guide applies to the following inverter models:

M50A_260 (RPI503M260000)

Product version L and M

Customer service contact details:

Delta Electronics (Netherlands) B.V.

Tscheulinstrasse 21

79331 Teningen

Germany

Authorized representative for this product in the EU:

Delta Electronics (Netherlands) B.V

Zandsteen 15

2132 MZ Hoofddorp

Netherlands

This Quick Installation Guide contains all the information required to install and commission the inverters. However, the guide is not intended to be used as a plan for the installation or commissioning process. The technical and legal provisions may also have altered since the production of this inverter. Therefore, before starting installation work, **always** consult solarsolutions.delta-emea.com to check whether a newer version of this Quick Installation Guide or the more detailed Installation and Operation Manual is available.

DANGER



Electric shock

Potentially fatal voltages are present in the inverter during operation. When the inverter is disconnected from all power sources, this voltage remains in the inverter for up to 60 seconds.

You should therefore always carry out the following steps before working on the inverter:

1. Turn both DC disconnectors to the **OFF** position.
2. Disconnect the inverter from all AC and DC voltage sources and make sure that none of the connections can be restored accidentally.
3. Wait at least 60 seconds for the internal capacitors to discharge.

DANGER



Electric shock

Potentially fatal voltages are present at the DC connections of the inverter. When light falls on the solar modules, they immediately start to generate electricity. This also happens when light does not fall directly on the solar modules.

- ▶ Never disconnect the inverter from the solar modules when it is under load.
- ▶ Turn both DC disconnectors to the **OFF** position.
- ▶ Disconnect the connection to the grid so that the inverter cannot feed energy into the grid.
- ▶ Disconnect the inverter from all AC and DC voltage sources. Make sure that none of the connections can be restored accidentally.
- ▶ Ensure that the DC cables cannot be touched accidentally.

DANGER



Electric shock

The inverter has a high leakage current value.

- ▶ **Always** connect the ground cable first, then the AC and DC cables.

WARNING



Electric shock

The IP66 protection degree is no longer guaranteed when the door is open.

- ▶ Only open the door when absolutely necessary.
- ▶ Do not open the door if water or dirt might enter the inverter.
- ▶ After work is completed, ensure that the door is properly shut and tightened again. Check that the door is properly sealed.

WARNING



Heavy weight

The inverter is heavy.

- ▶ Lift and carry the inverter with at least two people, or use a suitable lifting device.

WARNING



Hot surfaces

The surface of the inverter can get very hot during operation.

- ▶ Always wear safety gloves when touching the inverter.

NOTICE



Use of aluminum cables

- ▶ Always observe the applicable regulations and rules for the use of aluminum cables. For detailed information, refer to the complete Installation and Operation Manual.

NOTICE



Working in freezing conditions


In freezing conditions, the rubber seal on the front door can freeze to the housing and tear when opened.

- ▶ Before opening the front door, defrost the rubber seal with some warm air.

- To comply with IEC 62109-5.3.3 safety requirements and avoid injury or material damage, the inverter must be installed and operated in accordance with the safety and operating instructions set out in this manual. Delta Electronics is not responsible for damage resulting from failure to follow the safety and operating instructions set out in this manual.
- The inverter may only be installed and commissioned by installers who have been trained and approved for the installation and operation of grid-connected solar inverters.
- All repair work on the inverter must be carried out by Delta Electronics. Otherwise the warranty will be void.
- Warning notices, warning symbols and other markings attached to the inverter by Delta Electronics must not be removed.
- To avoid the risk of arcing, do not disconnect cables when the inverter is under load.
- To prevent damage due to lightning strikes, follow the applicable regulations in your country.
- All external connections must be sufficiently sealed in order to ensure an IP66 protection degree. Seal any unused connections with the cover caps supplied.
- The covers inside the inverter do **not** have to be removed for the standard installation. All connections required for the standard installation are also accessible with the covers attached.
- Only equipment in accordance with SELV (EN 60950) may be connected to the RS485 interfaces.


Scope of Delivery

INV-I




1x

INV-Q




1x


INV-X



1x





MOU-H



1x


Do not use any damaged components.

Scope of Delivery




DC-P+

Amphenol H4 – 4/6 mm²
DC+ (H4CFC4D•MS)
M50A: 12x




DC-P-

Amphenol H4 – 4/6 mm²
DC- (H4CMC4D•MS)
M50A: 12x




DC-T

2x




DC-B

6x




SUB-A

1x




SUB-M

1x




SUB-S


3x



Accessories and software




MOU-G



2x

MOU-S





4x


DOWNLOAD

partnerportal.delta-emea.com/en/portal-login.htm

Delta Service Software (DSS)




0,25 ... 1,5 mm²



RS485/USB Adapter

Accessories must be ordered separately.

A Windows PC with a RS485/USB adapter is required. Delta Service Software (DSS) must be installed on the PC.



Risk of death due to electric shock

Potentially fatal voltage is present inside the inverter during operation and this voltage remains for 60 seconds after the power supply is disconnected.



Before working on the inverter, read the supplied manual and follow the instructions provided.



The housing of the inverter must be grounded if local regulations require additional grounding or equipotential bonding.




The inverter has no galvanic isolation.





WEEE

The inverter may not be disposed of alongside normal household waste. Always follow the waste disposal regulations for electrical appliances in your country or region.





Dimensions





Dimensions














Installation











Installation










Installation



Communication card






RS485



Switch on the RS485 terminator resistor of the data logger or connect a termination resistor.

If the data logger does not have an integrated RS485 terminator resistor, connect the data logger in the middle of the RS485 bus.





Digital inputs 3

V1 K0 K1 K2 K3 K4 K5 K6


CAT5 / CAT6
 Ø 7,2 / 8,0 / 10,0 mm; 0,25 ... 1,5 mm²

Dry contacts 4

A B




Pin	Pin	
V1	-	-
K0	-	External power-off (EPO)
K1	V1 + K1	$P_{max} = 0\%$
K2	V1 + K1	$P_{max} = 30\%$
K3	V1 + K1	$P_{max} = 60\%$
K4	V1 + K1	$P_{max} = 100\%$
K5	Reserved	-
K6	Reserved	-

Connect a PC





Connect the PC to the inverter via the RS485/USB adapter.

Connecting the grid (AC)




Connecting the grid (AC)



Connecting the Solar Modules (DC)


DC-P+

Amphenol H4 – 4/6 mm²
DC+ (H4CFC4D•MS)
M50A: 12x




DC-P-

Amphenol H4 – 4/6 mm²
DC- (H4CMC4D•MS)
M50A: 12x




DC-T




2x

DC-B



6x


M50A



1


DC-B

+



2

Commissioning



The inverter must be supplied with alternating current (grid) and/or direct current (solar modules).



Start the software and commission the inverter.

Technical Data

Input (DC)	M50A
Maximum input power (per MPP Tracker/total)	11.7 kW / 58.0 kW
Rated power	50 kW
Input voltage range for operation	200 to 1000 V _{DC}
Maximum input voltage	1100 V _{DC} ¹⁾
Nominal voltage	600 V _{DC}
Number of MPP trackers	6
Total MPP input voltage range	200 to 1000 V _{DC}
Maximum input current (per MPP Tracker/total)	26 A/132 A
DC short-circuit current I _{SC}	50 A per MPP tracker
Open-circuit voltage V _{OC}	1000 V _{DC} /1100 V _{DC} without damage
DC connector panel	
Connector type	Amphenol H4 connector
Number of DC connections	12 pairs
DC cable specifications	4/6 mm ²
Use of external string fuses	1 or 2 strings per MPPT: No external string fuses required
Overvoltage category ²⁾	II
Surge protection devices	Type 2 (EN 50539-11), replaceable, combination type 1+2, upgradeable
Galvanic isolation	No
Output (AC)	M50A
Maximum apparent power	55 kVA ³⁾
Maximum active power	55 kW ³⁾⁴⁾
Rated apparent power	50 kVA ³⁾
Nominal voltage ⁵⁾	230/400 V -20%/+30%, 3 phases + PE (Δ), 3 phases + N + PE (Y)
Rated current	72.5 A
Maximum current	83 A
Frequency range ⁵⁾	50/60 Hz ± 5 Hz
Adjustment range power factor	0.8 cap. to 0.8 ind. (0.9 cap. to 0.9 ind. at maximum active power)
Total harmonic distortion	<3% at rated apparent power
Power consumption in night mode	<3.5 W ⁶⁾
AC connection	
Connector type	L1, L2, L3, N: Terminal with hexagon socket screw PE: M10 threaded bolt with nut
Copper cable specifications	25 to 60 mm ² (single wire, multi-wire, fine-wire with wire end sleeve)
Aluminum cable specifications	35 to 60 mm ² (round single wire, round multi-wire, sector shaped)
Overvoltage category ²⁾	III
Surge protection devices	Type 2 (EN 61463-11), replaceable, combination type 1+2, upgradeable
Mechanical details	M50A
Dimensions (W x H x D)	699 × 629 × 264 mm
Weight	64 kg
Cooling	1x fan module containing 3x fans for circulating ambient air, replaceable 2x internal fans for preventing heat buildup, replaceable
Mounting options	suspended (mounting plate included in the scope of delivery) free-standing (mounting feet available as an accessory)
Communication and Data Visualization	M50A
Communication interfaces	2 x RS485, 2 x Dry contacts, 1 x EPO, 1 x 12 V _{DC} power supply, 6 x digital inputs
Communication	RS485, Sub-1G, Wi-Fi (optional)
Communication protocols	Modbus RTU

General specifications	M50A
Delta model name	M50A_260
Delta part number	RPI503M260000
Overall operating temperature range	-25 to +60 °C
Relative humidity	0 to 100%, non-condensing
Max. operating height	4000 m above sea level
Noise level	<65 dB(A)

Standards and guidelines	M50A
Protection degree	IP66
Safety class	II
Pollution degree	II
Overload behavior	Current limitation, power limitation
Safety	IEC 62109-1/-2, CE compliance
EMC	EN 61000-6-2/-6-3/-3-11/-3-12
Noise immunity	IEC 61000-4-2/-3/-4/-5/-6/-8
Distortion factor	EN 61000-3-2
Voltage fluctuations and flicker	EN 61000-3-3
Grid connection guidelines	You will find the current list at solarsolutions.delta-emea.com

- 1) The maximum voltage withstand is 1100 V_{DC}. The inverter starts to work if the input voltage falls below 1000 V_{DC}.
- 2) IEC 60664-1, IEC 62109-1
- 3) For cos phi = 1 (VA = W)
- 4) At ambient temperatures ≤ 40°C
- 5) AC voltage and frequency range will be programmed according to the individual country requirements.
- 6) Power consumption with standby communication

Belgique/België	support.belgium@solar-inverter.com	0800 711 35 (toll free)
България	support.bulgaria@solar-inverter.com	+421 42 4661 333
Česká republika	podpora.czechia@solar-inverter.com	800 143 047 (toll free)
Danmark	support.danmark@solar-inverter.com	8025 0986 (toll free)
Germany	service.deutschland@solar-inverter.com	0800 800 9323 (toll free)
Ελλάδα	support.greece@solar-inverter.com	+49 7641 455 549
España	soporto.espana@solar-inverter.com	900 958 300 (toll free)
France	support.france@solar-inverter.com	0800 919 816 (toll free)
לארשי	supporto.israel@solar-inverter.com	800 787 920 (toll free)
Italia	supporto.italia@solar-inverter.com	800 787 920 (toll free)
Nederland	ondersteuning.nederland@solar-inverter.com	0800 022 1104 (toll free)
Austria	service.oesterreich@solar-inverter.com	0800 291 512 (toll free)
Polska	serwis.polska@solar-inverter.com	+48 22 335 26 00
Portugal	suporte.portugal@solar-inverter.com	+49 7641 455 549
Slovenija	podpora.slovenija@solar-inverter.com	+421 42 4661 333
Slovensko	podpora.slovensko@solar-inverter.com	0800 005 193 (toll free)
Schweiz/Suisse/Svizzera	support.switzerland@solar-inverter.com	0800 838 173 (toll free)
Türkiye	support.turkey@solar-inverter.com	+421 42 4661 333
United Kingdom	support.uk@solar-inverter.com	0800 051 4281 (toll free)
Other European countries	support.europe@solar-inverter.com	+49 7641 455 549



solarsolutions.delta-emea.com